

Description of Alternatives

Alternative 5										
Regulation Schedule	Deviation schedule for WCA-3A as specified by USACE including raising Zone D to Zone C from Nov 1 to Feb 11. No deviation in WCA-2A regulation schedule.									
S-343 A/B and S-344	Closed Nov 1 to July 15 independent of WCA-3A levels.									
S-12 A/B/C/D	S-12A closed Nov 1 to Jul 15; S-12B closed Jan 1 to Jul 15; S-12C closed Feb 1 to Jul 15; S-12D operated according to WCA-3A schedule. Follow WCA 3A regulation schedule after Jul 15.									
S-333: G-3273 < 6.8'	55% of the rainfall plan target to NESRS, plus as much of the remaining 45% that the S-12s can't discharge to be passed through S-334; and subject to capacity constraints, which are 1350 cfs at S-333, L-29 maximum stage limit, and canal stage limits downstream of S-334.									
S-333: G-3273 > 6.8'	No discharge to NESRS; release 55% of the rainfall plan target, plus as much of the remaining 45% that the S-12s can't discharge through S-333 and S-334, subject to capacity constraints.									
L-29 constraint	9.0 ft									
S-355A&B	<table border="0"> <tr> <td></td> <td style="text-align: center;">Dry</td> <td style="text-align: center;">Wet</td> </tr> <tr> <td>Open</td> <td style="text-align: center;">8.50</td> <td style="text-align: center;">8.50</td> </tr> <tr> <td>Close</td> <td style="text-align: center;">6.50</td> <td style="text-align: center;">6.50</td> </tr> </table>		Dry	Wet	Open	8.50	8.50	Close	6.50	6.50
	Dry	Wet								
Open	8.50	8.50								
Close	6.50	6.50								
S-337	Regulatory releases as per WCA-3A deviation schedule.									
S-151	Per the above WCA-3A regulation schedule.									
S-334	Same as in 95Base except that it also may pass all or part of S-333 releases to the SDCS, depending on stage at G-3273.									
S-332B	Pumped up to 500 cfs from Aug through Jan; 325 cfs in Feb, Jun, and July; and 125 cfs from Mar through May. <table border="0" style="margin-left: auto; margin-right: auto;"> <tr> <td></td> <td style="text-align: center;">Dry</td> <td style="text-align: center;">Wet</td> </tr> <tr> <td>On</td> <td style="text-align: center;">5.00</td> <td style="text-align: center;">4.70</td> </tr> <tr> <td>Off</td> <td style="text-align: center;">4.30</td> <td style="text-align: center;">4.00</td> </tr> </table>		Dry	Wet	On	5.00	4.70	Off	4.30	4.00
	Dry	Wet								
On	5.00	4.70								
Off	4.30	4.00								
S-332B Seepage Reservoir	160 acres with emergency overflow.									
S-332D	Pumped up to 500 cfs design capacity from Jul 16 to Nov 30; 325 cfs from Dec 1 to Jan 31; and 165 cfs from Feb 1 to Jul 15. <table border="0" style="margin-left: auto; margin-right: auto;"> <tr> <td></td> <td style="text-align: center;">Dry</td> <td style="text-align: center;">Wet</td> </tr> <tr> <td>On</td> <td style="text-align: center;">5.00</td> <td style="text-align: center;">4.70</td> </tr> <tr> <td>Off</td> <td style="text-align: center;">4.80</td> <td style="text-align: center;">4.20</td> </tr> </table>		Dry	Wet	On	5.00	4.70	Off	4.80	4.20
	Dry	Wet								
On	5.00	4.70								
Off	4.80	4.20								
S-332	Closed									
S-175	Closed									
S-194	Operated to maximize flood control discharges to coast <table border="0" style="margin-left: auto; margin-right: auto;"> <tr> <td></td> <td style="text-align: center;">Dry</td> <td style="text-align: center;">Wet</td> </tr> <tr> <td>Open</td> <td style="text-align: center;">4.70</td> <td style="text-align: center;">4.70</td> </tr> <tr> <td>Close</td> <td style="text-align: center;">4.20</td> <td style="text-align: center;">4.20</td> </tr> </table>		Dry	Wet	Open	4.70	4.70	Close	4.20	4.20
	Dry	Wet								
Open	4.70	4.70								
Close	4.20	4.20								
S-196	Operated to maximize flood control discharges to coast. <table border="0" style="margin-left: auto; margin-right: auto;"> <tr> <td></td> <td style="text-align: center;">Dry</td> <td style="text-align: center;">Wet</td> </tr> <tr> <td>Open</td> <td style="text-align: center;">4.70</td> <td style="text-align: center;">4.70</td> </tr> <tr> <td>Close</td> <td style="text-align: center;">4.20</td> <td style="text-align: center;">4.20</td> </tr> </table>		Dry	Wet	Open	4.70	4.70	Close	4.20	4.20
	Dry	Wet								
Open	4.70	4.70								
Close	4.20	4.20								
S-176	<table border="0" style="margin-left: auto; margin-right: auto;"> <tr> <td></td> <td style="text-align: center;">Dry</td> <td style="text-align: center;">Wet</td> </tr> <tr> <td>Open</td> <td style="text-align: center;">4.85</td> <td style="text-align: center;">4.80</td> </tr> <tr> <td>Close</td> <td style="text-align: center;">4.65</td> <td style="text-align: center;">4.70</td> </tr> </table>		Dry	Wet	Open	4.85	4.80	Close	4.65	4.70
	Dry	Wet								
Open	4.85	4.80								
Close	4.65	4.70								
S-18C	<table border="0" style="margin-left: auto; margin-right: auto;"> <tr> <td></td> <td style="text-align: center;">Dry</td> <td style="text-align: center;">Wet</td> </tr> <tr> <td>Open</td> <td style="text-align: center;">2.25</td> <td style="text-align: center;">2.25</td> </tr> <tr> <td>Close</td> <td style="text-align: center;">2.00</td> <td style="text-align: center;">2.00</td> </tr> </table>		Dry	Wet	Open	2.25	2.25	Close	2.00	2.00
	Dry	Wet								
Open	2.25	2.25								
Close	2.00	2.00								